

**NRC-CNRC CONSTRUCTION**

# Acoustic Testing - Changes Relative to a Bare 150 mm Thick Concrete Floor

Author: Jeffrey Mahn  
Report Number: A1-019524.6  
Report Date: 20/09/2022  
Contract Number: A1-019524  
Agreement Date: 30/03/2021



*This page was intentionally left blank*

# Acoustic Testing - Changes Relative to a Bare 150 mm Thick Concrete Floor

Author

---

On behalf of: Jeffrey Mahn  
Research Officer  
Building Envelope and Materials,  
NRC Construction Research Centre

Approved

---

Bradford Gover, Ph.D.  
Director, Research and Development  
Building Envelope and Materials,  
Intelligent Building Operations  
NRC Construction Research Centre

Report No: A1-019524.6  
Report Date: 20/09/2022  
Contract No: A1-019524  
Agreement date: 30/03/2021  
Program: BEM R&D

8 Pages

Copy 1 of 1

This report may not be reproduced in whole or in part without the written consent of the National Research Council Canada and the Client.

*This page was intentionally left blank*

This report shows the changes in the transmission loss, the normalized impact sound pressure levels and the fast weighted peak levels when five floor assemblies using AMC Mekanocaucho products were constructed on a 150 mm thick, solid concrete slab. In each case, the construction of the floor assembly is presented as well as the changes relative to the bare 150 mm thick, solid concrete slab.

The transmission loss, the normalized impact sound pressure levels and the fast weighted peak levels can be found in the following, separate reports:

Floor Assembly	Report Number
A1-019524-01F	A1-019524.1
A1-019524-02F	A1-019524.2
A1-019524-03F	A1-019524.3
A1-019524-04F	A1-019524.4
A1-019524-05F	A1-019524.5

**Client** AMC Mecanocaucho  
Pol. Industrial, Zone A - Pab 35.  
Asteasu E-20159, Gipuzkoa. Spain

- Specimen**
- 150 mm (6") Precast Concrete Slab
  - 17.5 mm (0.7") AMC Mechanocaucho Akustik + Sylomer Sound Clip 30
    - \* air gap 35 mm (1-3/8")
  - 22 mm (7/8") Furring Channel
    - \* thickness included in air gap above
  - 25 mm (1") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 16 mm (5/8") Type X Gypsum Board
  - 16 mm (5/8") Type X Gypsum Board

**Specimen ID** A1-019524-01F

## Specimen Description

**Structural:** A 150 mm (6") precast concrete slab was installed in the test frame. The perimeter was sealed from below with duct putty. The perimeter was filled from above with glass fibre insulation and sealed with cloth tape.

**Ceiling Clips:** The AMC Mecanocaucho Akustik + Sylomer sound clip 30 was installed at nominal 0.61 m x 1.22 m (24" x 48") intervals. The sound clips were fastened to the concrete slab via 19 mm (3/4") long machine screws for the centre hole and 32 mm (1-1/4"), 3/16" diameter tapcon concrete screws for the side holes. The sound clip depth was 17.5 mm (0.7") and with the addition of the support structure the total air gap was 35 mm (1-3/8").

**Ceiling Support Structure:** Each 22 mm (7/8") furring channel was installed and held in place by the Akustik + Sylomer sound clip 30 at 610 mm (24") intervals length-wise across the testing frame.

**Insulation:** One layer of 25 mm (1") thick glass fibre insulation was installed in the ceiling cavity.

**Ceiling:** Two layers of 16 mm (5/8") Type X gypsum board were installed for a total thickness of 32 mm (1-1/4"). The first layer (base layer) was installed perpendicular to the furring channels and fastened using 41 mm (1-5/8") #6 fine thread drywall screws in a 305 mm x 610 mm (12" x 24") spacing pattern. The second layer (face layer) was installed in the same orientation as the base layer and offset to prevent seams from overlapping. It was installed with 51 mm (2") #6 fine thread drywall screws using the same screw spacing as the base layer. The perimeter of the face layer was sealed with backer rod and caulking then covered with cloth tape. The seams of the face layer were sealed with caulking and covered with foil tape. Drywall screws on the face layer were covered with foil tape.




Figure 1 Cross section of A1-019524-01F.

### Specimen Properties

Element	Actual Thickness (mm)	Mass/Length, Area or Volume
150 mm (6") Precast Concrete Slab	155.6	370.6 kg/m <sup>2</sup>
17.5 mm (0.7") AMC Mechanocaucho Akustik + Sylomer Sound Clip 30	**35.0	119.3 grams/clip
22 mm (7/8") Furring Channel	*23.0	0.4 kg/m
25 mm (1") Glass Fibre Insulation	*25.4	9.3 kg/m <sup>3</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
<b>Total</b>	<b>222.6</b>	

\* The thicknesses of these elements do not contribute to the total specimen thickness.

\*\* Total cavity space thickness of the ceiling clips and support structure.

### Test Specimen Installation

- The exposed area of the floor specimen used for the calculations of the airborne sound transmission loss was 17.85 m<sup>2</sup> (4.71 m x 3.79 m).
- The total area of the floor assembly resting on top of the lip was 19.32 m<sup>2</sup> (4.88 m x 3.96 m).
- The mass per area of the elements above the lip was calculated using the total area (19.32 m<sup>2</sup>).
- The mass per area of the ceiling elements was calculated using the exposed area (17.85 m<sup>2</sup>).

### ASTM E90 Test Results – Airborne Sound Transmission Loss


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-01F

Test ID: TLF-22-008  
 Date of Test: 2022-03-11

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	173.1	24.5	41.0 - 41.8
Lower	179.4	20.4	35.2 - 35.5

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in Airborne TL (dB)
50	-6
63	-10
80	-7
100	-3
125	4
160	9
200	12
250	14
315	14
400	14
500	15 c
630	14
800	13
1000	13
1250	13 c
1600	12
2000	13
2500	12
3150	14 c
4000	13 *
5000	11 *
<b>Change in Sound Transmission Class</b>	<b>13</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Airborne sound transmission loss measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements”.**

**In the graph:**

The solid line is the change in the sound transmission loss for this specimen relative to the bare, 150 mm thick, solid concrete slab. A positive value for both the change in airborne sound transmission loss and the single number rating, the sound transmission class indicate an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. The reported values have been corrected according to the procedure outlined in ASTM E90-09. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the lower limit of airborne sound transmission loss.



### ASTM E492 Test Results – Normalized Impact Sound Pressure Levels


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-01F

Test ID: IIF-22-004  
 Date of Test: 2022-03-11

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	173.1	24.9 - 25.0	48.5 - 50.1
Lower	179.4	21.1 - 21.4	39.1 - 41.7

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in NISPL (dB)
50	4
63	10
80	7
100	-2
125	-5
160	-12
200	-13
250	-13
315	-16
400	-16
500	-16
630	-16
800	-15
1000	-16
1250	-16
1600	-15
2000	-15
2500	-16
3150	-16
4000	-17
5000	-18
<b>Change in Impact Insulation Class</b>	<b>16</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Measurements of normalized impact sound pressure level (NISPL) were conducted in accordance with the requirements of ASTM E492-09, “Standard Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine”.**

**In the graph:**

The solid line is the change in the normalized impact sound pressure level (NISPL) for this specimen relative to the bare, 150 mm thick, solid concrete slab. A decrease in the NISPL is an improvement. However, the single number rating, the impact insulation class is the opposite where a positive change in the impact insulation class is an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level and the reported values of NISPL provide an estimate of the upper limit of normalized impact sound pressure level, according to the procedure outlined in ASTM E492-09. The reported values of NISPL have been corrected according to the procedure outlined in ASTM E492-09.

### Fast Weighted Peak Levels – Heavy/Soft Impact Source (Ball)


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-01F

Test ID: HVF-22-004  
 Date of Test: 2022-03-11

	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	173.1	24.6 - 24.7	41.8 - 43.8
Lower	179.4	20.5 - 20.6	34.7 - 34.9

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in L <sub>IF,MAX</sub> (dB)
50	4
63	10
80	2
100	2
125	-5
160	-9
200	-11
250	-13 c
315	-16
400	-16
500	-16 *
630	-15 *
800	-15 c
1000	-14 c
1250	-14 *
1600	-13 *
2000	-13 *
2500	-12 *
3150	-9 *
4000	-7 *
5000	-5 *



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. See appendix "Heavy Impact Sound Transmission – Floor Facility" for more details on the test procedure.

**In the graph:**

The solid line is the change in the fast weighted peak levels (L<sub>IF,MAX</sub>) for this specimen. A decrease in the L<sub>IF,MAX</sub> value indicates an improvement when the linings were applied.

**In the table:**

Values marked "c" indicate that the measured background level was between 6 dB and 15 dB below the combined receiving room level and background level. The marked values of L<sub>IF,MAX</sub> have been corrected according to the procedure outlined in ISO 10140-4 section 4.3. Values marked "\*" indicate that the measured background level was less than 6 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the upper limit of L<sub>IF,MAX</sub>.

*This page was intentionally left blank*

**Client** AMC Mecanocaucho  
Pol. Industrial, Zone A - Pab 35.  
Asteasu E-20159, Gipuzkoa. Spain

- Specimen**
- 10 mm (3/8") Plywood
  - 19 mm (3/4") Plywood
  - 19 mm (3/4") Plywood
  - 89 mm (3-1/2") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 89 mm (3-1/2") Wood Studs (Wood Battens)
    - \* thickness included in cavity space depth below
  - 67.5 mm (2.7") AMC Mechanocaucho Akustik + Sylomer Floor Mount 25
    - \* cavity space depth 116 mm (4-9/16")
  - 150 mm (6") Precast Concrete Slab
  - 17.5 mm (0.7") AMC Mechanocaucho Akustik + Sylomer Sound Clip 30
    - \* air gap 35 mm (1-3/8")
  - 22 mm (7/8") Furring Channel
    - \* thickness included in air gap above
  - 25 mm (1") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 16 mm (5/8") Type X Gypsum Board
  - 16 mm (5/8") Type X Gypsum Board

**Specimen ID** A1-019524-02F

## Specimen Description

Covering: Three layers of plywood were installed, for a total thickness of 48 mm (1-7/8"). The first layer (base layer) was a 19 mm (3/4") sheet of plywood installed perpendicular to the wood studs (wood battens) and fastened with 51 mm (2") #8 construction wood screws at 305 mm (12") o.c. intervals along the wood studs (wood battens) and 305 mm (12") o.c. intervals along the perimeter. The second layer of plywood was the same thickness as the first layer and was installed in the same orientation as the first layer of plywood but offset by 305 mm (12"). The second layer was fastened to the wood studs (wood battens) through the first layer of plywood using 64 mm (2-1/2") #8 construction wood screws at the same spacing as the first layer. The third layer (face layer) was a 10 mm (3/8") plywood installed in the same orientation as the first two layers and again offset by 12". It was fastened to the wood studs (wood battens) through the first and second layers of plywood using 75 mm (3") #8 construction wood screws every 150 mm (6") o.c. along the seams and also fastened to the below layers of plywood every 150 mm (6") o.c. over the entire floor using 44 mm (1-3/4") #8 Torx screws. Glass fibre insulation was installed between the edges of the plywood and the test frame. The perimeter and the seams between the plywood sheets were sealed with cloth tape.

Floor Support Structure: The support structure was constructed of 2x4 wood studs (wood battens), actually 38 mm x 89 mm (1-1/2" x 3-1/2"), installed and fastened into the floor mounts length-wise across the test frame. Each wood stud (wood batten) was fastened to the floor mounts using 38 mm (1-1/2") #8 construction wood screws, with two on each side.

Floor Mounts: The AMC Mekanocaucho Akustik + Sylomer floor mount 25 was installed at nominal 600 mm x 600 mm (23-5/8" x 23-5/8") intervals, as shown in Figure 1. The floor mounts were fastened to the concrete slab using a fast fix adhesive. The floor mounts had a depth of 67.5 mm (2.7") and with the addition of the support structure the total cavity space depth was 116 mm (4-9/16").

Insulation: The cavities between the wood studs (wood battens) and floor mounts were filled with 89 mm (3-1/2") thick glass fibre insulation.

Structural: The 150 mm (6") precast concrete slab was installed in the test frame. The perimeter was sealed from below with duct putty. The perimeter was filled from above with glass fibre insulation and sealed with cloth tape.

Ceiling Clips: The AMC Mekanocaucho Akustik + Sylomer sound clip 30 was installed at nominal 0.61 m x 1.22 m (24" x 48") intervals. The sound clips were fastened to the concrete slab via 19 mm (3/4") long machine screws for the centre hole and 32 mm (1-1/4"), 3/16" diameter Tapcon concrete screws for the side holes. The sound clip depth was 17.5 mm (0.7") and with the addition of the support structure the total air gap was 35 mm (1-3/8").

Ceiling Support Structure: Each 22 mm (7/8") furring channel was installed and held in place by the Akustik + Sylomer sound clip 30 at 610 mm (24") intervals length-wise across the testing frame.

Insulation: One layer of 25 mm (1") thick glass fibre insulation was installed in the ceiling cavity.

Ceiling: Two layers of 15.9 mm (5/8") Type X gypsum board were installed for a total thickness of 31.8 mm (1-1/4"). The first layer (base layer) was installed perpendicular to the furring channels and fastened using 41 mm (1-5/8") #6 fine thread drywall screws in a 305 mm x 610 mm (12" x 24") spacing pattern. The second layer (face layer) was installed in the same orientation as the base layer and offset to prevent seams from overlapping. It was installed with 51 mm (2") #6 fine thread drywall screws using the same screw spacing as the base layer. The perimeter of the face layer was sealed with backer rod and caulking then covered with cloth tape. The seams of the face layer were sealed with caulking and covered with foil tape. Drywall screws on the face layer were covered with foil tape.




Figure 2 Floor mount installation layout.




Figure 3 Cross section of A1-019524-02F.

## Specimen Properties

Element	Actual Thickness (mm)	Mass/Length, Area or Volume
10 mm (3/8") Plywood	9.0	4.2 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
89 mm (3-1/2") Glass Fibre Insulation	*89.0	9.3 kg/m <sup>3</sup>
Nominal 2x4 Wood Studs (Wood Battens)	*89.0	1.6 kg/m
67.5 mm (2.7") AMC Mechanocaucho Akustik + Sylomer Floor Mount 25	**116.0	140.0 grams/mount
150 mm (6") Precast Concrete Slab	155.6	370.6 kg/m <sup>2</sup>
17.5 mm (0.7") AMC Mechanocaucho Akustik + Sylomer Sound Clip 30	***35.0	119.3 grams/clip
22 mm (7/8") Furring Channel	*23.0	0.4 kg/m
25 mm (1") Glass Fibre Insulation	*25.4	9.3 kg/m <sup>3</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
<b>Total</b>	<b>385.6</b>	

\* The thicknesses of these elements do not contribute to the total specimen thickness.

\*\* Total cavity space thickness of the floor mounts and support structure.

\*\*\* Total cavity space thickness of the ceiling clips and support structure.

## Test Specimen Installation

- The exposed area of the floor specimen used for the calculations of the airborne sound transmission loss was 17.85 m<sup>2</sup> (4.71 m x 3.79 m).
- The total area of the floor assembly resting on top of the lip was 19.32 m<sup>2</sup> (4.88 m x 3.96 m).
- The mass per area of the elements above the lip was calculated using the total area (19.32 m<sup>2</sup>).
- The mass per area of the ceiling elements was calculated using the exposed area (17.85 m<sup>2</sup>).

### ASTM E90 Test Results – Airborne Sound Transmission Loss


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-02F

Test ID: TLF-22-011  
 Date of Test: 2022-03-29

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	170.0	18.4	35.7 – 36.0
Lower	179.4	18.3	35.5

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in the Airborne TL (dB)
50	-11
63	-7
80	-1
100	6
125	14
160	18
200	20
250	23
315	21
400	23
500	24 *
630	25 c
800	23 c
1000	22 c
1250	20 *
1600	20 c
2000	21 c
2500	19 *
3150	18 *
4000	14 *
5000	11 *
<b>Change in the Sound Transmission Class</b>	<b>21</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Airborne sound transmission loss measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements”.**

**In the graph:**

The solid line is the change in the sound transmission loss for this specimen relative to the bare, 150 mm thick, solid concrete slab. A positive value for both the change in airborne sound transmission loss and the single number rating, the sound transmission class indicate an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. The reported values have been corrected according to the procedure outlined in ASTM E90-09. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the lower limit of airborne sound transmission loss.



### ASTM E492 Test Results – Normalized Impact Sound Pressure Levels


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-02F

Test ID: IIF-22-007  
 Date of Test: 2022-03-29

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	19.1	34.8 – 35.0
Lower	179.4	18.3	35.0 – 35.1

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in NISPL (dB)
50	0
63	0
80	-3
100	-13
125	-21
160	-31
200	-34
250	-36
315	-40
400	-44
500	-48
630	-51 c
800	-56 c
1000	-59 *
1250	-60 *
1600	-64 *
2000	-63 *
2500	-62 *
3150	-60 *
4000	-56 *
5000	-52 c
<b>Change in Impact Insulation Class</b>	<b>39</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Measurements of normalized impact sound pressure level (NISPL) were conducted in accordance with the requirements of ASTM E492-09, “Standard Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine”.**

**In the graph:**

The solid line is the change in the normalized impact sound pressure level (NISPL) for this specimen relative to the bare, 150 mm thick, solid concrete slab. A decrease in the NISPL is an improvement. However, the single number rating, the impact insulation class is the opposite where a positive change in the impact insulation class is an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level and the reported values of NISPL provide an estimate of the upper limit of normalized impact sound pressure level, according to the procedure outlined in ASTM E492-09. The reported values of NISPL have been corrected according to the procedure outlined in ASTM E492-09.

### Fast Weighted Peak Levels – Heavy/Soft Impact Source (Ball)


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-02F

Test ID: HVF-22-005  
 Date of Test: 2022-03-29

	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	19.1 – 19.2	34.3 – 34.7
Lower	179.4	18.3	35.1

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in L <sub>IF,MAX</sub> (dB)
50	6
63	6
80	-7
100	-10 c
125	-19 c
160	-26 *
200	-28 *
250	-28 *
315	-33 *
400	-34 *
500	-22 *
630	-24 *
800	-25 *
1000	-22 *
1250	-17 *
1600	-18 *
2000	-16 *
2500	-13 *
3150	-10 *
4000	-7 *
5000	-4 *



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. See appendix “Heavy Impact Sound Transmission – Floor Facility” for more details on the test procedure.

**In the graph:**

The solid line is the change in the fast weighted peak levels (L<sub>IF,MAX</sub>) for this specimen. A decrease in the L<sub>IF,MAX</sub> value indicates an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 6 dB and 15 dB below the combined receiving room level and background level. The marked values of L<sub>IF,MAX</sub> have been corrected according to the procedure outlined in ISO 10140-4 section 4.3. Values marked “\*” indicate that the measured background level was less than 6 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the upper limit of L<sub>IF,MAX</sub>.

*This page was intentionally left blank*

**Client** AMC Mecanocaucho  
 Pol. Industrial, Zone A - Pab 35.  
 Asteasu E-20159, Gipuzkoa. Spain

- Specimen**
- 10 mm (3/8") Plywood
  - 19 mm (3/4") Plywood
  - 19 mm (3/4") Plywood
  - 89 mm (3-1/2") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 89 mm (3-1/2") Wood Studs (Wood Battens)
    - \* thickness included in cavity space depth below
  - 67.5 mm (2.7") AMC Mechanocaucho Akustik + Sylomer Floor Mount 25
    - \* cavity space depth 116 mm (4-9/16")
  - 150 mm (6") Precast Concrete Slab

**Specimen ID** A1-019524-03F

## Specimen Description

Covering: Three layers of plywood were installed, for a total thickness of 48 mm (1-7/8"). The first layer (base layer) was a 19 mm (3/4") sheet of plywood installed perpendicular to the wood studs (wood battens) and fastened with 51 mm (2") #8 construction wood screws at 305 mm (12") o.c. intervals along the wood studs (wood battens) and 305 mm (12") o.c. intervals along the perimeter. The second layer of plywood was the same thickness as the first layer and was installed in the same orientation as the first layer of plywood but offset by 305 mm (12"). The second layer was fastened to the wood studs (wood battens) through the first layer of plywood using 64 mm (2-1/2") #8 construction wood screws at the same spacing as the first layer. The third layer (face layer) was a 10 mm (3/8") plywood installed in the same orientation as the first two layers and again offset by 12". It was fastened to the wood studs (wood battens) through the first and second layers of plywood using 75 mm (3") #8 construction wood screws every 150 mm (6") o.c. along the seams and also fastened to the below layers of plywood every 150 mm (6") o.c. over the entire floor using 44 mm (1-3/4") #8 Torx screws. Glass fibre insulation was installed between the edges of the plywood and the test frame. The perimeter and the seams between the plywood sheets were sealed with cloth tape.

Floor Support Structure: The support structure was constructed of 2x4 wood studs (wood battens), actually 38 mm x 89 mm (1-1/2" x 3-1/2"), installed and fastened into the floor mounts length-wise across the test frame. Each wood stud (wood batten) was fastened to the floor mounts using 38 mm (1-1/2") #8 construction wood screws, with two on each side.

Floor Mounts: The AMC Mecanocaucho Akustik + Sylomer floor mount 25 was installed at nominal 600 mm x 600 mm (23-5/8" x 23-5/8") intervals, as shown in Figure 1. The floor mounts were fastened to the concrete slab using a fast fix adhesive. The floor mounts had a depth of 67.5 mm (2.7") and with the addition of the support structure the total cavity space depth was 116 mm (4-9/16").

**Insulation:** The cavities between the wood studs (wood battens) and floor mounts were filled with 89 mm (3-1/2") thick glass fibre insulation.

**Structural:** The 150 mm (6") precast concrete slab was installed in the test frame. The perimeter was sealed from below with duct putty. The perimeter was filled from above with glass fibre insulation and sealed with cloth tape.




Figure 4 Floor mount installation layout.




Figure 5 Cross section of A1-019524-03F.

### Specimen Properties

Element	Actual Thickness (mm)	Mass/Length, Area or Volume
10 mm (3/8") Plywood	9.0	4.2 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
89 mm (3-1/2") Glass Fibre Insulation	*89.0	9.3 kg/m <sup>3</sup>
Nominal 2x4 Wood Studs (Wood Battens)	*89.0	1.6 kg/m
67.5 mm (2.7") AMC Mechanocaucho Akustik + Sylomer Floor Mount 25	**116.0	140.0 grams/mount
150 mm (6") Precast Concrete Slab	155.6	370.6 kg/m <sup>2</sup>
<b>Total</b>	<b>318.6</b>	

\* The thicknesses of these elements do not contribute to the total specimen thickness.

\*\* Total cavity space thickness of the floor mounts and support structure.

### Test Specimen Installation

- The exposed area of the floor specimen used for the calculations of the airborne sound transmission loss was 17.85 m<sup>2</sup> (4.71 m x 3.79 m).
- The total area of the floor assembly resting on top of the lip was 19.32 m<sup>2</sup> (4.88 m x 3.96 m).
- The mass per area of the elements above the lip was calculated using the total area (19.32 m<sup>2</sup>).
- The mass per area of the ceiling elements was calculated using the exposed area (17.85 m<sup>2</sup>).

### ASTM E90 Test Results – Airborne Sound Transmission Loss


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-03F

Test ID: TLF-22-013  
 Date of Test: 2022-03-31

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	20.9	41.0 - 41.1
Lower	176.9	18.4	48.1 - 49.1

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in the Airborne TL (dB)
50	-4
63	0
80	5
100	5
125	8
160	10
200	11
250	14
315	14
400	15
500	16
630	18
800	16
1000	15
1250	16 *
1600	17 c
2000	21 c
2500	19 *
3150	18 *
4000	15 *
5000	12 *
<b>Change in the Sound Transmission Class</b>	<b>13</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Airborne sound transmission loss measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements”.**

**In the graph:**

The solid line is the change in the sound transmission loss for this specimen relative to the bare, 150 mm thick, solid concrete slab. A positive value for both the change in airborne sound transmission loss and the single number rating, the sound transmission class indicate an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. The reported values have been corrected according to the procedure outlined in ASTM E90-09. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the lower limit of airborne sound transmission loss.

### ASTM E492 Test Results – Normalized Impact Sound Pressure Levels


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-03F

Test ID: IIF-22-009  
 Date of Test: 2022-03-31

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	21.2 – 21.2	39.0 – 39.5
Lower	176.9	18.2	45.1 – 45.2

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in NISPL (dB)
50	-5
63	-11
80	-10
100	-13
125	-16
160	-22
200	-24
250	-25
315	-28
400	-31
500	-32
630	-36
800	-41
1000	-45
1250	-50 c
1600	-59 *
2000	-61 *
2500	-62 *
3150	-60 *
4000	-57 *
5000	-52 *
<b>Change in Impact Insulation Class</b>	<b>39</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Measurements of normalized impact sound pressure level (NISPL) were conducted in accordance with the requirements of ASTM E492-09, “Standard Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine”.**

**In the graph:**

The solid line is the change in the normalized impact sound pressure level (NISPL) for this specimen relative to the bare, 150 mm thick, solid concrete slab. A decrease in the NISPL is an improvement. However, the single number rating, the impact insulation class is the opposite where a positive change in the impact insulation class is an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level and the reported values of NISPL provide an estimate of the upper limit of normalized impact sound pressure level, according to the procedure outlined in ASTM E492-09. The reported values of NISPL have been corrected according to the procedure outlined in ASTM E492-09.



### Fast Weighted Peak Levels – Heavy/Soft Impact Source (Ball)


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-03F

Test ID: HVF-22-008  
 Date of Test: 2022-03-31

	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	21.0	39.5 – 39.6
Lower	176.9	18.3	46.4 – 46.5

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in L <sub>IF,MAX</sub> (dB)
50	1
63	-3
80	-12
100	-10
125	-13
160	-16
200	-18 c
250	-20 c
315	-26 c
400	-28 c
500	-27 c
630	-28 *
800	-27 *
1000	-23 *
1250	-16 *
1600	-19 *
2000	-16 *
2500	-14 *
3150	-10 *
4000	-7 *
5000	-5 *



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. See appendix “Heavy Impact Sound Transmission – Floor Facility” for more details on the test procedure.

**In the graph:**

The solid line is the change in the fast weighted peak levels (L<sub>IF,MAX</sub>) for this specimen. A decrease in the L<sub>IF,MAX</sub> value indicates an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 6 dB and 15 dB below the combined receiving room level and background level. The marked values of L<sub>IF,MAX</sub> have been corrected according to the procedure outlined in ISO 10140-4 section 4.3. Values marked “\*” indicate that the measured background level was less than 6 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the upper limit of L<sub>IF,MAX</sub>.

*This page was intentionally left blank*

**Client** AMC Mecanocaucho  
 Pol. Industrial, Zone A - Pab 35.  
 Asteasu E-20159, Gipuzkoa. Spain

- Specimen**
- 10 mm (3/8") Plywood
  - 19 mm (3/4") Plywood
  - 19 mm (3/4") Plywood
  - 89 mm (3-1/2") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 89 mm (3-1/2") Wood Studs (Wood Battens)
    - \* thickness included in cavity space depth below
  - 67.5 mm (2.7") AMC Mecanocaucho Akustik + Sylomer Floor Mount 25
    - \* cavity space depth 116 mm (4-9/16")
  - 150 mm (6") Precast Concrete Slab
  - 254 mm (10") AMC Mecanocaucho SRS-25 + Sylomer Hanger
    - \* air gap 276 mm (10-7/8")
  - 38 mm (1-1/2") C-Channel
    - \* thickness included in air gap above
  - 22 mm (7/8") Furring Channel
    - \* thickness included in air gap above
  - 89 mm (3-1/2") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 16 mm (5/8") Type X Gypsum Board
  - 16 mm (5/8") Type X Gypsum Board

**Specimen ID** A1-019524-04F

### Specimen Description

Covering: Three layers of plywood were installed, for a total thickness of 48 mm (1-7/8"). The first layer (base layer) was a 19 mm (3/4") sheet of plywood installed perpendicular to the wood studs (wood battens) and fastened with 51 mm (2") #8 construction wood screws at 305 mm (12") o.c. intervals along the wood studs (wood battens) and 305 mm (12") o.c. intervals along the perimeter. The second layer of plywood was the same thickness as the first layer and was installed in the same orientation as the first layer of plywood but offset by 305 mm (12"). The second layer was fastened to the wood studs (wood battens) through the first layer of plywood using 64 mm (2-1/2") #8 construction wood screws at the same spacing as the first layer. The third layer (face layer) was a 10 mm (3/8") plywood installed in the same orientation as the first two layers and again offset by 12". It was fastened to the wood studs (wood battens) through the first and second layers of plywood using 75 mm (3") #8 construction wood screws every 150 mm (6") o.c. along the seams and also fastened to the below layers of plywood every 150 mm (6") o.c. over the entire floor using 44 mm (1-3/4") #8 Torx screws. Glass fibre insulation was installed between the edges of the plywood and the test frame. The perimeter and the seams between the plywood sheets were sealed with cloth tape.

Floor Support Structure: The support structure was constructed of 2x4 wood studs (wood battens), actually 38 mm x 89 mm (1-1/2" x 3-1/2"), installed and fastened into the floor mounts length-wise across the test frame. Each wood stud (wood batten) was fastened to the floor mounts using 38 mm (1-1/2") #8 construction wood screws, with two on each side.

Floor Mounts: The AMC Mecanocaucho Akustik + Sylomer floor mount 25 was installed at nominal 600 mm x 600 mm (23-5/8" x 23-5/8") intervals, as shown in Figure 1. The floor mounts were fastened to the concrete slab using a fast fix adhesive. The floor mounts had a depth of 67.5 mm (2.7") and with the addition of the support structure the total cavity space depth was 116 mm (4-9/16").

Insulation: The cavities between the wood studs (wood battens) and floor mounts were filled with 89 mm (3-1/2") thick glass fibre insulation.

Structural: The 150 mm (6") precast concrete slab was installed in the test frame. The perimeter was sealed from below with duct putty. The perimeter was filled from above with glass fibre insulation and sealed with cloth tape.

Ceiling Hangers: The AMC Mecanocaucho SRS-25 + Sylomer hangers were installed at nominal 1.22 m x 1.22 m (48" x 48") intervals. The hanger depth was set to 254 mm (10") so that with the addition of the support structure, the total air gap was 276 mm (10-7/8").

Ceiling Support Structure: 38 mm (1-1/2") C-channels were installed into the ceiling hanger clamps at 1.22 m (48") intervals width-wise across the testing frame. 22 mm (7/8") furring channels were installed and spaced perpendicular to the C-channels every 610 mm (24") o.c. and attached using two 11 mm (7/16") long self-drilling screws every 1.22 m (48") o.c.

Insulation: One layer 89 mm (3-1/2") thick glass fibre insulation was installed in the ceiling cavity.

Ceiling: Two layers of 16 mm (5/8") Type X gypsum board were installed for a total thickness of 32 mm (1-1/4"). The first layer (base layer) was installed perpendicular to the furring channels and fastened using 41 mm (1-5/8") #6 fine thread drywall screws in a 305 mm x 610 mm (12" x 24") spacing pattern. The second layer (face layer) was installed in the same orientation as the base layer and offset to prevent seams from overlapping. It was installed with 51 mm (2") #6 fine thread drywall screws using the same screw spacing as the base layer. The perimeter of the face layer was sealed with backer rod and caulking then covered with cloth tape. The seams of the face layer were sealed with caulking and covered with foil tape. Drywall screws on the face layer were covered with foil tape.




Figure 6 Floor mount installation layout.




Figure 7 Cross section of A1-019524-04F.

## Specimen Properties

Element	Actual Thickness (mm)	Mass/Length, Area or Volume
10 mm (3/8") Plywood	9.0	4.2 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
19 mm (3/4") Plywood	19.0	8.3 kg/m <sup>2</sup>
89 mm (3-1/2") Glass Fibre Insulation	*89.0	9.3 kg/m <sup>3</sup>
Nominal 2x4 Wood Studs (Wood Battens)	*89.0	1.6 kg/m
67.5 mm (2.7") AMC Mechanocaucho Akustik + Sylomer Floor Mount 25	**116.0	140.0 grams/mount
150 mm (6") Precast Concrete Slab	155.6	370.6 kg/m <sup>2</sup>
254 mm (10") AMC Mecanocaucho SRS-25 + Sylomer Hanger	***276.0	1.0 kg/hanger
38 mm (1-1/2") C-Channel	*38.0	0.5 kg/m
22 mm (7/8") Furring Channel	*23.0	0.4 kg/m
89 mm (3-1/2") Glass Fibre Insulation	*89.0	9.3 kg/m <sup>3</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
<b>Total</b>	<b>626.6</b>	

\* The thicknesses of these elements do not contribute to the total specimen thickness.

\*\* Total cavity space thickness of the floor mounts and support structure.

\*\*\* Total cavity space thickness of the ceiling hangers and support structure.

## Test Specimen Installation

- The exposed area of the floor specimen used for the calculations of the airborne sound transmission loss was 17.85 m<sup>2</sup> (4.71 m x 3.79 m).
- The total area of the floor assembly resting on top of the lip was 19.32 m<sup>2</sup> (4.88 m x 3.96 m).
- The mass per area of the elements above the lip was calculated using the total area (19.32 m<sup>2</sup>).
- The mass per area of the ceiling elements was calculated using the exposed area (17.85 m<sup>2</sup>).

### ASTM E90 Test Results – Airborne Sound Transmission Loss


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-04F

Test ID: TLF-22-016  
 Date of Test: 2022-04-21

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	21.3	46.2 – 46.4
Lower	173.7	18.6 – 18.7	41.6 – 41.9

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in the Airborne TL (dB)
50	0
63	11
80	18
100	19
125	27
160	28
200	30
250	37 c
315	35
400	36 c
500	34 *
630	32 c
800	31 *
1000	30 *
1250	23 *
1600	27 *
2000	26 *
2500	22 *
3150	21 *
4000	16 *
5000	13 *
<b>Change in the Sound Transmission Class</b>	<b>32</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Airborne sound transmission loss measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements”.**

**In the graph:**

The solid line is the change in the sound transmission loss for this specimen relative to the bare, 150 mm thick, solid concrete slab. A positive value for both the change in airborne sound transmission loss and the single number rating, the sound transmission class indicate an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. The reported values have been corrected according to the procedure outlined in ASTM E90-09. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the lower limit of airborne sound transmission loss.

### ASTM E492 Test Results – Normalized Impact Sound Pressure Levels


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-04F

Test ID: IIF-22-010  
 Date of Test: 2022-04-21

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	21.3 - 21.4	49.9 - 52.3
Lower	173.7	18.7 - 18.8	44.4 - 45.3

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in NISPL (dB)
50	-12
63	-19
80	-23
100	-31
125	-34
160	-39
200	-44
250	-47
315	-51
400	-56 c
500	-60 c
630	-62 *
800	-65 *
1000	-66 *
1250	-59 *
1600	-65 *
2000	-63 *
2500	-63 *
3150	-60 *
4000	-57 *
5000	-52 *
<b>Change in Impact Insulation Class</b>	<b>57</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Measurements of normalized impact sound pressure level (NISPL) were conducted in accordance with the requirements of ASTM E492-09, “Standard Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine”.**

**In the graph:**

The solid line is the change in the normalized impact sound pressure level (NISPL) for this specimen relative to the bare, 150 mm thick, solid concrete slab. A decrease in the NISPL is an improvement. However, the single number rating, the impact insulation class is the opposite where a positive change in the impact insulation class is an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level and the reported values of NISPL provide an estimate of the upper limit of normalized impact sound pressure level, according to the procedure outlined in ASTM E492-09. The reported values of NISPL have been corrected according to the procedure outlined in ASTM E492-09.



### Fast Weighted Peak Levels – Heavy/Soft Impact Source (Ball)


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-04F

Test ID: HVF-22-009  
 Date of Test: 2022-04-21

	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.0	21.4	46.9 – 48.2
Lower	173.7	18.7	42.8 – 43.2

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in L <sub>IF,MAX</sub> (dB)
50	-4
63	-9
80	-19
100	-22
125	-24 c
160	-26 c
200	-29 c
250	-26 c
315	-33 c
400	-32 *
500	-26 *
630	-19 *
800	-21 *
1000	-21 *
1250	-15 *
1600	-18 *
2000	-12 *
2500	-9 *
3150	-8 *
4000	-6 *
5000	-4 *



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. See appendix “Heavy Impact Sound Transmission – Floor Facility” for more details on the test procedure.

**In the graph:**

The solid line is the change in the fast weighted peak levels (L<sub>IF,MAX</sub>) for this specimen. A decrease in the L<sub>IF,MAX</sub> value indicates an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 6 dB and 15 dB below the combined receiving room level and background level. The marked values of L<sub>IF,MAX</sub> have been corrected according to the procedure outlined in ISO 10140-4 section 4.3. Values marked “\*” indicate that the measured background level was less than 6 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the upper limit of L<sub>IF,MAX</sub>.

*This page was intentionally left blank*

**Client** AMC Mecanocaucho  
Pol. Industrial, Zone A - Pab 35.  
Asteasu E-20159, Gipuzkoa. Spain

- Specimen**
- 150 mm (6") Precast Concrete Slab
  - 254 mm (10") AMC Mecanocaucho SRS-25 + Sylomer Hanger
    - \* air gap 276 mm (10-7/8")
  - 38 mm (1-1/2") C-Channel
    - \* thickness included in air gap above
  - 22 mm (7/8") Furring Channel
    - \* thickness included in air gap above
  - 89 mm (3-1/2") Glass Fibre Insulation
    - \* does not contribute to assembly thickness
  - 16 mm (5/8") Type X Gypsum Board
  - 16 mm (5/8") Type X Gypsum Board

**Specimen ID** A1-019524-05F

## Specimen Description

**Structural:** The 150 mm (6") precast concrete slab was installed in the test frame. The perimeter was sealed from below with duct putty. The perimeter was filled from above with glass fibre insulation and sealed with cloth tape.

**Ceiling Hangers:** The AMC Mecanocaucho SRS-25 + Sylomer hangers were installed at nominal 1.22 m x 1.22 m (48" x 48") intervals. The hanger depth was set to 254 mm (10") so that with the addition of the support structure, the total air gap was 276 mm (10-7/8").

**Ceiling Support Structure:** 38 mm (1-1/2") C-channels were installed into the ceiling hanger clamps at 1.22 m (48") intervals width-wise across the testing frame. 22 mm (7/8") furring channels were installed and spaced perpendicular to the C-channels every 610 mm (24") o.c. and attached using two 11 mm (7/16") long self-drilling screws every 1.22 m (48") o.c.

**Insulation:** One layer 89 mm (3-1/2") thick glass fibre insulation was installed in the ceiling cavity.

**Ceiling:** Two layers of 16 mm (5/8") Type X gypsum board were installed for a total thickness of 32 mm (1-1/4"). The first layer (base layer) was installed perpendicular to the furring channels and fastened using 41 mm (1-5/8") #6 fine thread drywall screws in a 305 mm x 610 mm (12" x 24") spacing pattern. The second layer (face layer) was installed in the same orientation as the base layer and offset to prevent seams from overlapping. It was installed with 51 mm (2") #6 fine thread drywall screws using the same screw spacing as the base layer. The perimeter of the face layer was sealed with backer rod and caulking then covered with cloth tape. The seams of the face layer were sealed with caulking and covered with foil tape. Drywall screws on the face layer were covered with foil tape.




Figure 8 Cross section of A1-019524-05F.

### Specimen Properties

Element	Actual Thickness (mm)	Mass/Length, Area or Volume
150 mm (6") Precast Concrete Slab	155.6	370.6 kg/m <sup>2</sup>
254 mm (10") AMC Mecanocaucho SRS-25 + Sylomer Hanger	**276.0	1.0 kg/hanger
38 mm (1-1/2") C-Channel	*38.0	0.5 kg/m
22 mm (7/8") Furring Channel	*23.0	0.4 kg/m
89 mm (3-1/2") Glass Fibre Insulation	*89.0	9.3 kg/m <sup>3</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
16 mm (5/8") Type X Gypsum Board	16.0	10.9 kg/m <sup>2</sup>
<b>Total</b>	<b>463.6</b>	

\* The thicknesses of these elements do not contribute to the total specimen thickness.

\*\* Total cavity space thickness of the ceiling hangers and support structure.

### Test Specimen Installation

- The exposed area of the floor specimen used for the calculations of the airborne sound transmission loss was 17.85 m<sup>2</sup> (4.71 m x 3.79 m).
- The total area of the floor assembly resting on top of the lip was 19.32 m<sup>2</sup> (4.88 m x 3.96 m).
- The mass per area of the elements above the lip was calculated using the total area (19.32 m<sup>2</sup>).
- The mass per area of the ceiling elements was calculated using the exposed area (17.85 m<sup>2</sup>).

### ASTM E90 Test Results – Airborne Sound Transmission Loss


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-05F

Test ID: TLF-22-021  
 Date of Test: 2022-04-29

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.3	20.5	39.0 - 39.2
Lower	173.7	18.2	38.7 - 39.2

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in the Airborne TL (dB)
50	1
63	9
80	11
100	12
125	14
160	16
200	18
250	20
315	20
400	21
500	23
630	22
800	20
1000	19
1250	19 c
1600	20 c
2000	20 c
2500	19 c
3150	20 *
4000	16 *
5000	12 *
<b>Change in the Sound Transmission Class</b>	<b>20</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Airborne sound transmission loss measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements”.**

**In the graph:**

The solid line is the change in the sound transmission loss for this specimen relative to the bare, 150 mm thick, solid concrete slab. A positive value for both the change in airborne sound transmission loss and the single number rating, the sound transmission class indicate an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. The reported values have been corrected according to the procedure outlined in ASTM E90-09. Values marked “\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the lower limit of airborne sound transmission loss.

### ASTM E492 Test Results – Normalized Impact Sound Pressure Levels


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-05F

Test ID: IIF-22-013  
 Date of Test: 2022-04-28

Room	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.3	21.2 – 21.2	55.8 – 57.3
Lower	173.7	18.5 – 18.6	42.6 – 43.2

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in the NISPL (dB)
50	-5
63	-10
80	-13
100	-14
125	-16
160	-18
200	-19
250	-19
315	-22
400	-24
500	-25
630	-24
800	-23
1000	-24
1250	-25
1600	-26
2000	-24
2500	-27
3150	-31
4000	-32
5000	-34
<b>Change in the Impact Insulation Class</b>	<b>29</b>



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. **Measurements of normalized impact sound pressure level (NISPL) were conducted in accordance with the requirements of ASTM E492-09, “Standard Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine”.**

**In the graph:**

The solid line is the change in the normalized impact sound pressure level (NISPL) for this specimen relative to the bare, 150 mm thick, solid concrete slab. A decrease in the NISPL is an improvement. However, the single number rating, the impact insulation class is the opposite where a positive change in the impact insulation class is an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 5 dB and 10 dB below the combined receiving room level and background level. Values marked “\*\*” indicate that the measured background level was less than 5 dB below the combined receiving room level and background level and the reported values of NISPL provide an estimate of the upper limit of normalized impact sound pressure level, according to the procedure outlined in ASTM E492-09. The reported values of NISPL have been corrected according to the procedure outlined in ASTM E492-09.

### Fast Weighted Peak Levels – Heavy/Soft Impact Source (Ball)


Client: AMC Mecanocaucho  
 Specimen ID: A1-019524-05F

Test ID: HVF-22-012  
 Date of Test: 2022-04-28

	Volume (m <sup>3</sup> )	Air Temperature (°C)	Humidity (%)
Upper	174.3	21.1	50.0 to 51.1
Lower	173.7	18.5	40.7 to 41.5

Area S of test specimen:	17.85	m <sup>2</sup>
--------------------------	-------	----------------

f (Hz)	Change in L <sub>IF,MAX</sub> (dB)
50	-4
63	-4
80	-12
100	-12
125	-15
160	-16
200	-18
250	-19
315	-20
400	-23
500	-24 c
630	-23 c
800	-22 c
1000	-21 *
1250	-17 *
1600	-18 *
2000	-16 *
2500	-14 *
3150	-10 *
4000	-7 *
5000	-5 *



For a description of the test specimen and mounting conditions see text pages before. The results in this report apply only to the specific sample submitted for measurement. No responsibility is assumed for performance of any other specimen. See appendix “Heavy Impact Sound Transmission – Floor Facility” for more details on the test procedure.

**In the graph:**

The solid line is the change in the fast weighted peak levels (L<sub>IF,MAX</sub>) for this specimen. A decrease in the L<sub>IF,MAX</sub> value indicates an improvement when the linings were applied.

**In the table:**

Values marked “c” indicate that the measured background level was between 6 dB and 15 dB below the combined receiving room level and background level. The marked values of L<sub>IF,MAX</sub> have been corrected according to the procedure outlined in ISO 10140-4 section 4.3. Values marked “\*” indicate that the measured background level was less than 6 dB below the combined receiving room level and background level, in which case, the corrected values provide an estimate of the upper limit of L<sub>IF,MAX</sub>.

## APPENDIX: ASTM E90-09 – Airborne Sound Transmission – Floor Facility

**Facility and Equipment:** The NRC Construction Floor Sound Transmission Facility comprises two reverberation rooms (referred to in this report as the upper and lower rooms) with a moveable test frame between the rooms. Both rooms have an approximate volume of 175 m<sup>3</sup>. In each room, there are eight pre-polarized diffuse-field ½" microphones, Brüel & Kjær Type 4942. Measurements are made in both rooms simultaneously using a NI PXI-4499 DAQ system with LabVIEW measurement software. Each room has four bi-amped loudspeakers driven by separate amplifiers and noise sources. To increase diffusivity of the sound field, there are fixed diffusing panels in each room.

**Test Procedure:** Airborne sound transmission measurements were conducted in accordance with the requirements of ASTM E90-09, “Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.” Airborne sound transmission loss tests were performed in the forward (receiving room is the lower room) and reverse (receiving room is the upper room) directions. Results presented in this report are the average of the tests in these two directions. In each case, sound transmission loss values were calculated from the average sound pressure levels of both the source and receiving rooms and the average reverberation times of the receiving room. One-third octave band sound pressure levels were measured for thirty-two seconds at eight microphone positions in each room and then averaged to get the average sound pressure level in each room. Ten sound decays were averaged for each of eight microphones located in the respective receiving rooms; these eight reverberation times were averaged to get the average reverberation times for each room. Information on the flanking limit of the facility and reference specimen test results are available on request.

**Significance of Test Results:** ASTM E90-09 requires measurements in one-third octave bands in the frequency range 100 Hz to 5000 Hz. The standard recommends making measurements and reporting results over a larger frequency range, and this report presents such results, which may be useful for expert evaluation of the specimen performance. The precision of results outside the 100 Hz to 5000 Hz range has not been established, but is expected to depend on laboratory-specific factors.

**Sound Transmission Class (STC):** The Sound Transmission Class (STC) was determined in accordance with ASTM E413-16, “Classification for Rating Sound Insulation”. It is a single-number rating scheme intended to rate the acoustical performance of a partition element separating offices or dwellings. The higher the value of the rating, the better the performance. The rating is intended to correlate with subjective impressions of the sound insulation provided against the sounds of speech, radio, television, music, and similar sources of noise characteristic of offices and dwellings. The STC is of limited use in applications involving noise spectra that differ markedly from those referred to above (for example, heavy machinery, power transformers, aircraft noise, motor vehicle noise). Generally, in such applications it is preferable to consider the source levels and insulation requirements for each frequency band.

**In Situ Performance:** Ratings obtained by this standard method tend to represent an upper limit to what might be measured in a field test, due to structure-borne transmission (“flanking”) and construction deficiencies in actual buildings.



## APPENDIX: ASTM E492-09 – Light Impact Sound Transmission – Floor Facility

**Facility and Equipment:** The NRC Construction Floor Sound Transmission Facility comprises two reverberation rooms (referred to in this report as the upper and lower rooms) with a moveable test frame between the two rooms. Both rooms have an approximate volume of 175 m<sup>3</sup>. For impact sound transmission, only the lower room is used. In each room, there are 8 pre-polarized diffuse-field 1/2" microphones, Brüel & Kjær Type 4942. Measurements are made in both rooms simultaneously using a NI PXI-4499 DAQ system with LabVIEW measurement software. Each room has four bi-amped loudspeakers driven by separate amplifiers and noise sources. To increase diffusivity of the sound field, there are fixed diffusing panels in each room.

**Test Procedure:** Impact sound transmission measurements were conducted in accordance with ASTM E492-09, "Standard Test Method for Laboratory Measurement of Impact Sound Transmission through Floor-Ceiling Assemblies Using the Tapping Machine." This method uses a standard tapping machine placed at four prescribed positions on the floor. One-third octave band sound pressure levels were measured for thirty-two seconds at each microphone position in the receiving room and then averaged to get the average sound pressure level in the room. Ten sound decays were averaged for each of eight microphones located in the respective receiving rooms; these eight reverberation times were averaged to get the average reverberation times for each room. Information on the flanking limit of the facility and reference specimen test results are available on request. The spatial average sound pressure levels and reverberation times of the receiving room were used to calculate the Normalized Impact Sound Pressure Levels. Information on the flanking limit of the facility and reference specimen test results are available on request.

**Significance of Test Results:** ASTM E492-09 requires measurements in one-third octave bands in the frequency range 100 Hz to 3150 Hz. The standard recommends making measurements and reporting results over a larger frequency range, and this report presents such results, which may be useful for expert evaluation of the specimen performance. The precision of results outside the standard ranges has not been established, and is expected to depend on laboratory-specific factors such as room size and specimen dimensions.

**Impact Insulation Class (IIC):** The Impact Insulation Class (IIC) was determined in accordance with ASTM E989-21, "Standard Classification for Determination of Impact Insulation Class (IIC)". It is a single-number rating scheme intended to rate the effectiveness of floor-ceiling assemblies at preventing the transmission of impact sound from the standard tapping machine. A higher IIC value indicates a better floor performance.

**In Situ Performance:** Ratings obtained by this standard method tend to represent an upper limit to what might be measured in a field test, due to structure-borne transmission ("flanking") and construction deficiencies in actual buildings.

## APPENDIX: Heavy Impact Sound Transmission – Floor Facility

**Facility and Equipment:** The NRC Construction Floor Sound Transmission Facility comprises two reverberation rooms (referred to in this report as the upper and lower rooms) with a moveable test frame between the two rooms. Both rooms have an approximate volume of 175 m<sup>3</sup>. For impact sound transmission, only the lower room is used. In each room, there are eight pre-polarized diffuse-field 1/2" microphones, Brüel & Kjær Type 4942. Measurements are made in both rooms simultaneously using a NI PXI-4499 DAQ system with LabVIEW measurement software. Each room has four bi-amped loudspeakers driven by separate amplifiers and noise sources. To increase diffusivity of the sound field, there are fixed diffusing panels in each room.

**Test Procedure:** Impact tests were conducted following the recommendations in ISO 10140-3:2010 Annex A. A heavy/soft impact source described in Annex F of ISO 10140-5:2010 was dropped from a height of 100 cm over five different positions, on quarter lengths of both floor diagonals and in the centre of the room. Receive levels in the room below were measured simultaneously at eight different microphone positions as fast-weighted (125 ms) peak levels in one-third octave bands ( $L_{iF,MAX}$ ). The  $L_{iF,MAX}$  values measured at the different microphone positions were energy averaged for each excitation position. Then, the calculated fast weighted peak levels of all excitation positions were also energy averaged. One-third octave band background sound pressure levels were measured for thirty -two seconds at each microphone position in the receiving room and then averaged to get the average background sound pressure level in the room.

**Significance of Test Results:** The precision of results has not been established, and is expected to depend on laboratory-specific factors such as room size, sound absorption and specimen dimensions. The results are specific to the room in which they were measured, and an increase in volume and/or sound absorption reduces the measured fast weighted levels.

**In Situ Performance:** Levels obtained by this method tend to represent an upper limit to what might be measured in a field test with the same volume and absorption, due to structure-borne transmission (“flanking”) and construction deficiencies in actual buildings.